


Intertek **CERTIFICATE**
FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2200628

Control circuit devices and switching elements - AC contactors

Type designation: SA-3P-***_***

Certificate holder: Mingguang Hecheng Electrical Co., Ltd.
No.21, Hongwu Road, Mingguang Industry Park, Mingguang City, Anhui
239400 China

The product complies with the standard(s): EN IEC 60947-4-1:2019

Date of expiry: 20 May, 2027

EU Directive information: According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm


Signed:  **Date:** 20 May, 2022

Quan Li

APPENDIX:

Reference No. SE-S-2200628

Technical Data:

Type designation SA-3P-***-***
 Rated voltage (V) 415, 690V~
 Frequency (Hz) 50/60Hz
 Poles No. 3P
 Trademark 

Test Report 220200148SHA-001, -002
 Product information All types of contactors have the same basic design.
 Two frame sizes:
 I: SA-3P-50A-***, SA-3P-60A-***
 II: SA-3P-75A-***, SA-3P-90A-***

Main circuit:


Type	SA-3P-50A-***	SA-3P-60A-***	SA-3P-75A-***	SA-3P-90A-***
	Ue (V)/ Ie (A)	Ue (V)/ Ie (A)	Ue (V)/ Ie (A)	Ue (V)/ Ie (A)
AC-8a	415/50	415/60	415/75	415/90
AC-8b	415/18	415/22	415/27	415/34
AC-1	415/65	415/75	415/90	415/120
AC-3	415/50	415/60	415/75	415/90
	690/32	690/32	690/39	690/47
Ith (A)	65	75	90	120
Ir (A)	5000	5000	5000	5000
Iq (A)	50000	50000	50000	50000

Coil code:

Coil voltage (V a.c.)	24	120	240	277	380	480	575
Frequency (Hz)	50/60	50/60	50/60	50/60	50/60	50/60	50/60

Explanation for the mode / type:

SA - 3P - *** - ***



APPENDIX:

Reference No. SE-S-2200628

Manufacturing Sites: Mingguang Hecheng Electrical Co., Ltd.
No.21, Hongwu Road, Mingguang Industry Park, Mingguang City, Anhui
239400 China

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU. This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 20 May, 2022

Quan Li

Intertek